

ml

CITY OF MOUNTAIN VIEW

SFUND RECORDS CTR
2807-91845

CM-DPW-ADPW
SE-OE-Planning
Bldg-PWS-WDE
F/y

SFUND RECORDS CTR
88172017

Public Works

April 10, 1967

Union Carbide Corporation
365 Middlefield Road
Mountain View, California 94040

Attention Mr. E. Routhier, Plant Engineer

Gentlemen:

We have received your transmittal of April 6, 1967 having to do with the Industrial waste treatment facility you propose to use.

The Building Department has no record of a plumbing permit for the installation of the sewer line you now have connected to the lateral on the unimproved frontage between your two plant sites.

The Planning Department informs us that no site plan approval has been given for installation of a waste treatment facility on this same unimproved parcel.

We suggest that you clear with both Planning and the Building Departments prior to proceeding any further with the installation of waste facilities. As you are no doubt aware, permits for construction will also be required for the concrete vault and the incidental plumbing.

As far as the physical facilities proposed for waste treatment are concerned we are unable to approve these until further data is submitted regarding flow rates, chemicals involved and metals which may be in solution.

There is no positive means shown on your drawings SK246 of preventing discharge of untreated or inadequately treated waste to the City's system. We would suggest a mechanical or electrical interlock to prevent opening either tank valve until proper neutralization has been accomplished.

A sampling manhole on the waste effluent line will be necessary. This can be utilized as the required cleanout if properly located.

Your attention is directed to Ordinance No. 175.638, a copy of which was forwarded to Union Carbide in September 1966.

Very truly yours,

GEORGE L. McPHEETERS
Water Division Engineer